Ultrasonic Testing on Duplex Stainless Steel







GE imagination at work

Presented by R.Baskar, AMIE (Mech) ASNT NDT Level III RT,UT,PT & MT CSWIP 3.2 AWS – SCWI





Calibration Block for UT Equipment





3 **GE Confidential and Proprietary Information** GE©2007 All Rights Reserved





4 GE Confidential and Proprietary Information GE©2007 All Rights Reserved







Amplitude or Sensitivity Calibration





Summary

✓ The material used for calibration blocks, have the same acoustic properties as the material to be tested. (Reference: DNV-OS-F101, para. 204, page- 201)

- The metal velocity difference is only 100 m/sec
- Austenitic Stainless Steel material Velocity = 5780 m/sec
- Duplex Stainless Steel material velocity = 5880 m/sec
- The difference in the position of indications at time base scale is only
 0.85mm, which can be ignored

Thanks

✓ For Amplitude or Sensitivity Calibration, reference reflector (SDH) in the reference block has been used.





GE Confidential and Proprietary Information GE©2007 All Rights Reserved